

STORMWATER DEVELOPMENT SITE REVIEW CHECKLIST

City of Lawton • Public Works Department Stormwater Management 212 SW 9th Street • Lawton, Oklahoma 73501 Phone (580) 581-3360 • Fax (580) 581-3479 WWW.Lawtonok.gov

Name of Development: Wise House				
Address: 3660 SW 45 th Street		Floodplain: N		
Legal Description: Meets and Bounds		Size of Tract: 5.0 Ac.		
Area to be disturbed: 0.25 Ac.	Date Review Completed: 11-24-21 MH	Approved: N		

Pla	ns Adequate:	Y	Ν
I. General Information	-		
1. Legal description on site plan		/	
2. Location and dimension of all property lines		/	
3. Plans drawn to scale		/	
4. Names of all surrounding streets		/	
5. Primary or secondary channel or floodway on site?		-	
6. Drainage off-site improvements required?		-	
7. Earth change permit required? (See earth change permit review checklist)		-	
8. Fill proposed within top of bank of blue-line stream (USACE 404 Permit)?			
9. Dam proposed? OWRB permit required? Meet jurisdictional size requirement?		-	
II. Stormwater Runoff			
1. Calculations for all areas provided?			/
2. All stormwater runoff discharge locations for the site identified for existing conditions			/
3. All stormwater runoff discharge locations for the site identified for proposed conditions			/
4. Drainage area for stormwater runoff at each discharge location of the site for existing conditions			/
5. Drainage area for stormwater runoff at each discharge location of the site for proposed conditions			/
6. Stormwater peak flow rate at each discharge location of the site for existing conditions			/
7. Stormwater peak flow rate at each discharge location of the site for proposed conditions			/
8. Stormwater velocity at each discharge location of the site for existing conditions			/
9. Stormwater velocity at each discharge location of the site for proposed conditions			/
10. Historical runoff conditions unchanged?			/
11. Size and location of existing or proposed drainage structures (stormwater storage facilities		/	
channels, etc). If proposed, submit calculations used to size the system as well as cross-sections and			
construction details.			
III. Flow in Streets			
1. Calculations provided for all locations?			
2. Flow depth in streets: Arterial-4" for 100-year, Collector-5" for 25-year, Residential-6" for 10-year			
3. 1' freeboard to structures provided for 100-year			
4. Drainage area shall not exceed 20 acres			
IV. Bridges, Culverts and Enclosed Storm Sewers			
1. Calculations provided for all structures?			
2. Bridge opening or pipe size			
B. Materials			
V. Open Drainage Channels			
1. Calculations provided?			
2. Channel sizing			
3. Materials		-	

City of Lawton Stormwater Development Site Review Checklist

VI. Sump Position Floo	d Protection		
1. Adequate freeboard provided?		-	
VII. Development Grad	ing		
1. Existing and propose	ed contours provided?	-	
2. Direction of storm water drainage <u>on</u> and <u>around</u> the site indicated with existing and proposed spot		-	
	elevations, contours and arrows. Do not concentrate flow on adjacent properties. Proposed drainage		
	ffect adjacent ownership.		
	rotection provided and sized?	-	
4. Existing upstream runoff passing through site allowed to continue?		-	
VIII. Stormwater Stora			
1. Calculations provided?			/
2. O&M manual			/
	sing through detention structure or bypass?		/
IX. Erosion and Sedime			
1. Earth change permit submittal provided? (See earth change permit review checklist)		-	
X. Post-Construction			
1. Calculations provide	d?	-	
2. BMPs to treat WQv		-	
3. O&M manual		-	
XI. Floodplain Manager			
	permit application provided?	-	
	substantial improvement?	-	
	tion at location of development	-	
4. Finished floor elevat		-	
	fringe delineation on plans	-	
6. Fill proposed in floo	dway? No-rise certification?	-	
1	es consistent with FIRM and field conditions?	-	
8. Physical floodway de		-	
9. HEC-RAS models pr	rovided	-	
10. LOMC required?		-	
	inundation map to development along East Cache Creek	-	
12. Floodplain zoning re		-	
13. Critical Facility? If	so, add to GIS layer	-	

CORRECTION OF ALL NOTED DEFICIENCIES IS REQUIRED PRIOR TO ISSUANCE OF AN EARTH CHANGE OR BUILDING PERMIT.

REVIEW COMMENTS:

1. Provide drainage calculations for site as required in City of Lawton Standard Drainage Policy. Show that historical runoff characteristics are unchanged as required in LCC 19A-1-2-123. A fee in lieu of stormwater detention may be paid in place of drainage calculations and detention for this project. If this option is used, please submit a request in writing as required in LCC 19A-1-2-124.

PRIOR TO OBTAINING A CERTIFICATE OF OCCUPANCY THE OWNER SHALL:

- 1. Complete construction of all required drainage facilities and erosion control as detailed on the approved site or development plan.
- 2. Provide <u>"as built" plans</u> both digital and hard copy based on field survey data of the public or private streets, storm sewers, detention facilities, and all other conveyances of stormwater; a revised set of drainage <u>calculations</u> that correspond with the "as-built" plans; and a <u>letter</u> of certification stating that the "as-built" site complies with all governing ordinances and adopted drainage standards of the City of Lawton.

- 3. Submit an approved Operation and Maintenance (O&M) Manual applicable to the operation and maintenance of the detention facility and/or post-construction water quality best management practices (BMPs). The O&M Manual shall address inspection frequency and the fundamental requirements of safe operation and maintenance of the facility. A listing of improvements and structures and the required maintenance of each shall be included in the O&M Manual. Indicate in the manual to keep inspection records on file for a minimum of five years.
- 4. Provide final stabilization for the site. Provide an established uniform perennial vegetative cover (e.g., evenly distributed without large bare areas), which covers 70% or more of the density of coverage that was provided by vegetation prior to commencing earth-disturbing activities.

