



EXHIBIT A
NEIGHBORHOOD SERVICES DIVISION
212 SW 9TH STREET
Lawton, Oklahoma 73501
(580) 581-3467 FAX (580) 581-3510
PROPERTY MAINTENANCE EVALUATION WORKSHEET

The following property is in violation of Lawton City Code 6-5-1; Existing Structures Code, as described in this attachment:

Inspection Date: Sept. 3, 2020

Address: 911 SW 37TH ST.

Type of Occupancy: RESIDENTIAL

Vacant structure and premises is not maintained in a clean, safe, secure and sanitary condition; Creating blight problem or adversely affecting the public health and safety. (IPMC 301.3)

Weeds plant growth in excess of 12 inches (IPMC 302.4, as amended by LCC 15-2)

Insect and rodent harborage and/or infestation (IPMC 302.5 & 308.1)

Exterior surface lacks protective treatment from the elements, decay and rust; peeling, flaking and chipped paint; missing, cracked or broken siding. (IPMC 304.2)

Foundation walls not plumb; open cracks and breaks; openings that allow animals to enter (IPMC 304.5)

Exterior walls have holes, breaks, or other loose or rotting materials (IPMC 304.6)

Roof, roof drains, gutters, and downspouts in disrepair, inadequate to prevent dampness or deterioration in walls and interior portion of the structure; roof water discharging in a manner that creates a public nuisance. (IPMC 304.7)

Decorative features (cornices, trim, wall facings, etc.) in disrepair, improperly anchored, unsafe. (IPMC 304.8)

Windows, skylights, and door-frames cracked, not weather tight, unable to open, disrepair (IPMC 304.13)

Lacking insect screens where required for ventilation; existing screens in disrepair (IPMC 304.14)

Doors, door assemblies and hardware in poor condition, unlocked, poor condition (IPMC 304.15)

Interior of structure and equipment not maintained in good repair, structurally sound and in a sanitary condition. (IPMC 305.1)

Interior surfaces poorly maintained unclean, unsanitary, decayed wood, peeling paint, cracked or loose plaster. (IPMC 305.3)

Exterior property and premises, and the interior of every structure not free of any accumulation of rubbish and garbage. (IPMC 307.1)

NOTES: VACANT STRUCTURE. WINDOWS AND DOORS ARE BOARDED UP. THERE IS TALL GRASS AND THE MAIN STRUCTURE HAS DAMAGE THROUGHOUT. THIS STRUCTURE DOES NOT HAVE CITY WATER. PHOTOS WERE TAKEN.

Inspected By: Daniel Lynch and Corey Bowen

This inspection sheet is not intended to be all-inclusive and additional items may be identified and corrected to bring the property in compliance with the Lawton City Code.