



## Legislation Details (With Text)

<b>File #:</b>	21-555	<b>Version:</b>	1
<b>Type:</b>	Consent Agenda	<b>Status:</b>	Agenda Ready
<b>File created:</b>	10/5/2021	<b>In control:</b>	City Council
<b>On agenda:</b>	10/26/2021	<b>Final action:</b>	
<b>Title:</b>	Consider acknowledging receipt of a permit from the Oklahoma Department of Environmental Quality for the construction of 6 linear feet of six (6) inch PVC pipe for fire line, 153 linear feet of eight (8) inch PVC pipe for water line distribution and all appurtenances to serve the Storage Depot Waterline Extension, Comanche County, Oklahoma.		
<b>Sponsors:</b>			
<b>Indexes:</b>			
<b>Code sections:</b>			
<b>Attachments:</b>	1. ODEQ Permit Storage Depot Waterline Extension		

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

### ITEM TITLE:

Consider acknowledging receipt of a permit from the Oklahoma Department of Environmental Quality for the construction of 6 linear feet of six (6) inch PVC pipe for fire line, 153 linear feet of eight (8) inch PVC pipe for water line distribution and all appurtenances to serve the Storage Depot Waterline Extension, Comanche County, Oklahoma.

### INITIATOR:

Richard Rogalski, Deputy City Manager

### STAFF INFORMATION SOURCE:

Kameron Good, Planner I

### BACKGROUND:

On September 24, 2021 the City of Lawton was granted Permit No. WL000016210643 for the construction of 6 linear feet of six (6) inch PVC pipe for fire line, 153 linear feet of eight (8) inch PVC pipe for water line distribution and all appurtenances to serve the Storage Depot Waterline Extension, Comanche County, Oklahoma. The project authorized by this permit should be constructed in accordance with the plans approved by this Department on September 24, 2021. Any deviations from the approved plans and specifications affecting capacity, flow or operation of units must be approved, in writing, by the Department before changes are made. A condition of the permit is that it must be noted in the minutes of the next regular meeting of the Lawton City Council.

**EXHIBIT:** Permit

**KEY ISSUES:** N/A

**FUNDING SOURCE:** N/A

**STAFF RECOMMENDED COUNCIL ACTION:**

Acknowledge receipt of Permit No. WL000016210643 from the Oklahoma Department of Environmental Quality.